



LABORATÓRIO NACIONAL  
DE ENGENHARIA CIVIL

LABORATÓRIO NACIONAL DE ENGENHARIA CIVIL, I. P.  
Av. do Brasil 101 • 1700-066 LISBOA • PORTUGAL  
phone: (351) 21 844 30 00  
e-mail: [lnec@lnec.pt](mailto:lnec@lnec.pt) • [www.lnec.pt](http://www.lnec.pt)



Member of



[www.eota.eu](http://www.eota.eu)

## European Technical Assessment

**ETA 19/0481**  
of 28/02/2022

English translation prepared by LNEC; original version in Portuguese language

ISSN 2183-3362

Trade name of the construction  
product

*Designação comercial do produto de construção*

Product family to which the  
construction product belongs

*Família de produtos a que o produto de  
construção pertence*

Manufacturer

*Fabricante*

Manufacturing plant(s)

*Instalações de fabrico*

This European Technical Assessment  
contains

*A presente Avaliação Técnica Europeia contém*

This European Technical Assessment is  
issued in accordance with Regulation  
(EU) No. 305/2011, on the basis of

*Esta Avaliação Técnica Europeia é emitida ao  
abrigo do Regulamento (UE) n.º 305/2011, com  
base no*

This European Technical Assessment

*A presente Avaliação Técnica Europeia*

### ISOVIT CORK

External Thermal Insulation Composite System with rendering  
on expanded cork for use as external insulation of building walls

*Sistema Compósito de Isolamento Térmico pelo Exterior com revestimento  
aplicado sobre isolante térmico de aglomerado de cortiça expandida destinado  
ao isolamento exterior de paredes de edifícios*

SECIL MARTINGANÇA, S.A.

Rua do Mercado

Gândara

2405-017 Maceira

Leiria

Portugal

[www.secilargamassas.pt](http://www.secilargamassas.pt)

Rua do Mercado

Gândara

2405-017 Maceira

Leiria

Portugal

15 pages, including 3 annexes which form an integral part of  
this assessment

*15 páginas, incluindo 3 anexos que fazem parte desta avaliação*

European Assessment Document - EAD 040083-00-0404:  
External thermal insulation composite systems (ETICS) with  
renderings, January 2019

*Documento de Avaliação Europeia - EAD 040083-00-0404:  
Sistemas compósitos de Isolamento Térmico pelo exterior (ETICS)  
com revestimento, janeiro de 2019*

Replaces ETA 19/0481, issued on 30/09/2019

*Substitui a ETA 19/0481, emitida em 30/09/2019*

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

This European Technical Assessment may be withdrawn by the issuing Technical Assessment Body, in particular pursuant to information by the Commission according to Article 25, Paragraph 3, of Regulation (EU) No. 305/2011.

## 1. Technical description of the product

The External Thermal Insulation Composite System (from now on, referred to as ETICS) ISOVIT CORK is designed and installed in accordance with the manufacturer's design and installation instructions, deposited with LNEC<sup>1</sup>.

ISOVIT CORK is a bonded system with supplementary mechanical fixings used primarily to provide stability until the adhesive has dried and to increase the adherence of the system reducing the risk of detachment.

The ETICS comprises the components identified in Table 1, which are factory produced by the manufacturer or a supplier.

It is made up on site from these components. The manufacturer is ultimately responsible for the ETICS.

## 2. Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

This ETICS is intended to be used as external thermal insulation for building walls. The walls are made of masonry (bricks or blocks) or concrete (cast on site or as prefabricated panels) with a reaction to fire classification A1 to A2-s2,d0 according to EN 13501-1 or A1 according to the EC decision 96/603/EC as amended. The ETICS is designed to give the wall to which is applied satisfactory thermal insulation.

The ETICS is made of non load-bearing construction elements. It does not contribute directly to the stability of the wall on which is installed, but it can contribute to its durability by providing enhanced protection from the effect of weathering. The thermal resistance of the ETICS shall be  $\geq 1,0 \text{ m}^2 \text{ K/W}$ .

This ETICS can be used on new or existing (retrofit) vertical walls. It can also be used on horizontal or inclined surfaces which are not exposed to precipitation.

The ETICS is not intended to ensure the air tightness of the building structure.

Design and installation of ETICS should take into account the principles laid down in EAD 040083-00-0404 (see 1.1) and shall be done in accordance with national instructions. This ETA covers the application of bonded ETICS where the concrete for testing of bond strength is representative for masonry or concrete. For bonded applications onto other substrates (e.g. organic paints or ceramic tiles), testing on the job site is necessary.

The provisions made in this ETA are based on an assumed working life of at least 25 years, provided that the conditions laid down for the installation, appropriate use, maintenance and repair are met.

The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right product in relation to the expected economically reasonable working life of the works.

### Installation

The ETICS is installed on site. It is the responsibility of the manufacturer to guarantee that the information about design and installation of this ETICS is effectively communicated to the concerned people. This information can be given using reproductions of the respective parts of this European Technical Assessment. Besides, all the data concerning the execution shall be clearly indicated on the packaging and/or the enclosed instruction sheets using one or several illustrations.

The wall on which the ETICS is applied shall be sufficiently stable and airtight. Its stiffness shall be big enough to ensure that the ETICS is not subjected to deformations, which could lead to damage. The requirements given in EAD 040083-00-0404 (see 1.3.1) have to be considered.

<sup>1</sup> The technical documentation of this European Technical Assessment is deposited with Laboratório Nacional de Engenharia Civil (LNEC) and, as far as relevant for the tasks of the notified body (bodies) involved in the assessment and verification of constancy of performance procedure, is handed over to the notified body (bodies).

**TABLE 1**  
**Definition of the components**

Components	Trade name	Description <sup>1</sup>	Coverage (kg/m <sup>2</sup> )	Thickness (mm)
Insulation product	ISOVIT ICB	Expanded cork (ICB) Panels with 1000 mm × 500 mm and bulk density of 100 kg/m <sup>3</sup> , with CE marking	–	40 to 300
Adhesive	ISOVIT E-CORK	Mortar based on mixed binders, cork aggregates and natural hydraulic lime, with CE marking	6 to 6.5	–
Base coat	ISOVIT E-CORK	Mortar based on mixed binders, cork aggregates and natural hydraulic lime, with CE marking with standard glassfibre	7 to 8.5	3 to 3.5
		Mortar based on mixed binders, cork aggregates and natural hydraulic lime, with CE marking with standard and reinforced glassfibre	10 to 13	4 to 6
Finishing coats	F1	REABILITA CAL AC	Mortar composed by natural hydraulic lime and siliceous and calcareous aggregates, with CE marking	4 to 5
		ISOVIT AD 25	Key coat based on silicate watery dispersion	0.10 to 0.30
		ISOVIT REV SP	Paint based on silicate watery dispersion	0.30 to 0.50
	F2	ISOVIT AD 20	Anti-alkaline key coat based on acrylic resin and mineral fillers	0.25 to 0.35
		ISOVIT REV	Finishing coat based on acrylic resin	1 to 2
Glass fibre meshes	ISOVIT REDE 160		Standard mesh, glass fibre mesh with mesh size 5 mm × 4 mm (in accordance with Agrément Certificate DH 942 by LNEC)	–
	ISOVIT REDE 343		Reinforced mesh, glass fibre mesh with mesh size 6 mm × 6 mm (in accordance with Agrément Certificate DH 942 by LNEC)	–
Anchors (supplementary mechanical fixings)	ISOVIT BUCHA	Description in accordance with ETA 16/0509 <sup>2</sup> Remain under the manufacturer responsibility	–	–
Ancillary materials		Description in accordance with clause 1.3.13 of EAD 040083-00-0404 Remain under the manufacturer responsibility		

<sup>1</sup> See clause 3.2 for further description, characteristics and performances of components.

<sup>2</sup> ETA based on ETAG 014, used as EAD.

### Design

The user shall comply with the national regulations and particularly concerning fire and wind load resistance. Only the components described in clause 1 with characteristics according to clause 3 of this ETA can be used for this ETICS.

The works including the details (such as connections and joints) shall be designed in order to avoid water penetration behind the system. To bond the ETICS, the minimum surface area and the method of bonding shall comply with the characteristics of the ETICS (see 3.2.4 of this ETA) as well as the national regulations. In any case, the minimum surface shall be at least 40%.

### Execution

The recognition and preparation of the substrate as well as the generalities about the execution of the ETICS shall be carried out in compliance with the manufacturer prescriptions and the corresponding national regulations.

The particularities in execution linked to the method of bonding and the application of the rendering system shall be handled in accordance with manufacturer's prescriptions. In particular it is suitable to comply with the quantities of rendering applied, the thickness regularity and the drying periods between layers.

### Use, maintenance and repair of the works

It is accepted that the finishing coats shall normally be maintained in order to fully preserve the system's performance. Maintenance will include at least:

- the repair of localized damaged areas due to accidents;
- the application of various products or paints, possibly after washing or surface preparation.

Necessary repairs should be done rapidly. It is important to be able to carry out maintenance as far as possible using readily available products and equipment, without spoiling appearance.

## 3. Performance of the product and references to the methods used for its assessment

### 3.1 General

The identification tests and the assessment for the intended use of this ETICS according to the Essential Requirements were carried out in compliance with EAD 040083-00-0404.

### 3.2 ETICS characteristics

#### 3.2.1 Mechanical resistance and stability (BWR 1)

Not relevant.

#### 3.2.2 Safety in case of fire (BWR 2)

##### a) Reaction to fire (EAD 040083-00-0404 – clause 2.2.1.1)

The reaction to fire was tested according to EN 13823 and EN 11925-2 and classified according to EN 13501-1+A1.

The ETICS meets the requirements of class B-s1,d0 according to EN 13501-1+A1.

Note: In some Member States, the ETICS classification according to EN 13501-1+A1 might not be sufficient for the use in façades. An additional assessment of ETICS according to national provisions (e.g. on the basis of a large scale test) might be necessary to comply with Member State regulations.

#### 3.2.3 Hygiene, health and environment (BWR 3)

##### a) Water absorption (EAD 040083-00-0404 – clause 2.2.5.1)

The results of the water absorption test of the base coat (system with and without finishing), presented in Table 2, verify the following condition:

- water absorption after 1 hour < 1 kg/m<sup>2</sup>

The system is therefore judged to have satisfactory performance concerning water absorption, independently of the finishing coat.

**TABLE 2**  
Water absorption (capillarity test)

System specimens	Water absorption after 1 h (kg/m <sup>2</sup> )	Water absorption after 24 h (kg/m <sup>2</sup> )
ICB + base coat + standard mesh	Min.: 0.08 Average: 0.20	Min.: 0.47 Average: 0.48
ICB + base coat + standard mesh + finishing coat F1 (REABILITA CAL AC + ISOVIT AD 25 + ISOVIT REV SP)	Min.: 0.05 Average: 0.05	Min.: 0.44 Average: 0.44
ICB + base coat + standard mesh + finishing coat F2 (ISOVIT AD 20 + ISOVIT REV)	Min.: 0.01 Average: 0.10	Min.: 0.48 Average: 0.52

##### b) Hygrothermal behaviour (EAD 040083-00-0404 – clause 2.2.6)

The ETICS has been assessed on a rig including the thermal insulation and all top two coats.

During heat-rain and heat-cold cycles, none of the following defects occurs during testing:

- blistering or peeling of the finishing coat, base coat or rendering system;
- failure or cracking associated with joints between insulation product boards or profiles fitted with the system;
- detachment of finishing coat, base coat or rendering system;
- cracking allowing water penetration to the insulation layer.

The ETICS is therefore assessed as resistant to hygrothermal cycles.

c) Freeze / thaw behaviour (EAD 040083-00-0404 – clause 2.2.7)

The water absorption of the system configurations composed by the base coat and the finishing coat F1 (REABILITA CAL AC + ISOVIT AD 25 + ISOVIT REV SP) and by the base coat and the finishing coat F2 (ISOVIT AD 20 + ISOVIT REV) is respectively less and higher than 0.5 kg/m<sup>2</sup> after 24 hours.

The system can therefore be assessed as freeze/thaw resistant without any further testing for the configuration composed by the base coat and the finishing coat F1.

d) Impact resistance (EAD 040083-00-0404 – clause 2.2.8)

The resistance to hard body impact (3 and 10 Joules) tests carried out on samples of systems compositions lead to the use categories presented in Table 3.

**TABLE 3**  
Impact resistance to hard body impacts

System	Impact	Impact diameter (mm)	Presence of cracks	Use categorie <sup>1</sup>
ICB + base coat + standard mesh	3 J	Average: 21	no cracking	II
	10 J	Average: 43	cracking and no penetration	
ICB + base coat + standard mesh + reinforced mesh	3 J	Average: 16	no cracking	I
	10 J	Average: 30	no cracking	

<sup>1</sup> Use categories:

Category I – zones readily accessible at ground level to the public and vulnerable to hard body impacts but not subjected to abnormally rough use;

Category II – zones liable to impacts from thrown or kicked objects, but in public locations where the height of the system will limit the size of the impact; or at lower levels where access to the building is primarily to those with some incentive to exercise care.

e) Water vapour permeability (EAD 040083-00-0404 – clause 2.2.9.1)

Table 4 presents the resistance to water vapour diffusion of the rendering system (base coat and finishing coat) for the two system configurations, expressed by the equivalent air thickness. In both cases, values don't exceed 2.0 m.

**TABLE 4**  
Equivalent air thickness

System specimens	Equivalent air thickness (m)
Base coat + standard mesh + finishing coat F1 (REABILITA CAL AC + ISOVIT AD 25 + ISOVIT REV SP)	0.8
Base coat + standard mesh + finishing coat F2 (ISOVIT AD 20 + ISOVIT REV)	1.3

f) Dangerous substances

This system complies with the provisions of Guidance Paper H<sup>2</sup>. A declaration of conformity in this respect was made by the manufacturer. In addition to the specific clauses relating to dangerous substances contained in this ETA, there may be other requirements applicable to the ETICS falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of Regulation (EU) No. 305/11, these requirements need also to be complied with, when and where apply.

### 3.2.4 Safety on use (BWR 4)

a) Bond strength

– Base coat onto ICB board (EAD 040083-00-0404 – clause 2.2.11.1)

Tests were performed on the system applied on the rig, after hygrothermal cycles. The results are summarized in Table 5.

In all cases, bond strength values are higher than 80 kPa and the failure occurred in the insulation board (cohesion failure).

<sup>2</sup> Guidance Paper H, A harmonized approach related to dangerous substances under the Construction Products Directive.

**TABLE 5**  
Bond strength between base coat and insulation product

System (rig) <sup>1</sup>	Bond strength (after ageing) (kPa / Failure pattern) <sup>2</sup>
ICB + base coat + standard mesh	Min.: 80 Average: 100 / FP: C
ICB + base coat + standard mesh + reinforced mesh	Min.: 80 Average: 100 / FP: C
ICB + base coat + standard mesh + finishing coat F1 (REABILITA CAL AC + ISOVIT AD 25 + ISOVIT REV SP)	Min.: 130 Average: 140 / FP: C
ICB + base coat + standard mesh + reinforced mesh + finishing coat F1 (REABILITA CAL AC + ISOVIT AD 25 + ISOVIT REV SP)	Min.: 80 Average: 120 / FP: C
ICB + base coat + standard mesh + finishing coat F2 (ISOVIT AD 20 + ISOVIT REV)	Min.: 100 Average: 120 / FP: C
ICB + base coat + standard mesh + reinforced mesh + finishing coat F2 (ISOVIT AD 20 + ISOVIT REV))	Min.: 130 Average: 140 / FP: C

1 Rig – system applied on brick masonry with tested dimensions of 3 m × 2 m. The system was subjected to hygrothermal cycles before the adhesion tests.

2 Failure pattern: FP:C – cohesion failure (failure in the insulation product).

– Adhesive onto ICB board (EAD 040083-00-0404 – clause 2.2.11.3)

Tests were performed on samples of ICB insulation boards faced with adhesive base coat product. The results are summarized in Table 6. In all cases, the failure occurred in the insulation board (cohesion failure).

**TABLE 6**  
Bond strength between adhesive and insulation product

Specimen	Bond strength (kPa / Failure pattern) <sup>1</sup>		
	Initial state	After conditioning	
		48 h immersion in water + 2 h 23 °C/50% RH	48 h immersion in water + 7 days 23 °C/50% RH
ICB + adhesive	Min.: 80 Average: 80 / FP:C	Min.: 30 Average: 60 / FP: C	Min.: 50 Average: 60 / FP:C

1 Failure pattern: FP:C – cohesion failure (failure in the insulation product).

– Adhesive/Base coat onto concrete (EAD 040083-00-0404 – clause 2.2.11.2)

Tests were performed on samples of concrete boards faced with adhesive/base coat product. The results are summarized in Table 7. In all cases, the failure occurred in the adhesive / base coat (cohesion failure).

**TABLE 7**  
Bond strength between adhesive and substrate (concrete)

Specimen	Bond strength (kPa / Failure pattern) <sup>1</sup>		
	Initial state	After conditioning	
		48 h immersion in water + 2 h 23 °C/50% RH	48 h immersion in water + 7 days 23 °C/50% RH
Adhesive + substrate (concrete)	Min.: 340 Average: 380 / FP:B	Min.: 230 Average: 280 / FP:B	Min.: 520 Average: 910 / FP:B

1 Failure pattern: FP:B – cohesion failure (failure in the adhesive).

The minimal bonded surface S is calculated as follows:

$$S (\%) = [30 * 100] / B$$

where:

B minimum mean failure resistance of the adhesive to the insulation product in dry conditions expressed in kPa (80 kPa);  
30 kPa corresponds to the minimum requirement.

The minimum bonded surface S is therefore 37,5%.

The bonding surface of 40% verifies the minimum requirement.

b) Wind load resistance (EAD 040083-00-0404 – clause 2.2.13)

Specimen: base coat bonded to the insulation board with adhesive (30% of bonding surface); thickness of the insulation board: 60 mm.

Table 8 presents the results of the dynamic wind uplift test.

None of the following defects occurred during the testing:

- break of the insulation panels;
- delamination in the insulation product or between the insulation product and its facing;
- detachment of the rendering system;
- pulling off a fastener of the insulation panel;
- tearing out of the substrate of a mechanical fastener;
- detachment of the insulation panel from the supporting structure.

So, no failure was observed at the maximum test suction of 7000 N.

The admissible suction is therefore:  $R_d > (7.0 * 0.9) / 1.5 = 4.2$  kPa.

**TABLE 8**  
Wind load resistance test

Number of cycles	Suction (kPa)
4	1.00
1	1.50
1	2.00
1	2.50
1	3.00
1	3.50
1	4.00
1	4.50
1	5.00
1	5.50
1	6.00
1	6.50
1	7.00

### 3.2.5 Protection against noise (BWR 5)

Single number improvement values have been determined by testing (EAD 040083-00-0404 – clause 2.2.22.1).

Table 9 presents the test results, and the ETICS configuration and substrate characteristics for which the values are valid.

**TABLE 9**  
Airborne sound insulation

Insulation product	Rendering system	ETICS fixing	Substrate	ETICS performance
Expanded cork (ICB) Thickness: 60 mm Maximum dynamic stiffness: NPD Air flow resistance: NPD	Minimum mass: 7.5 kg/m <sup>2</sup>	Bonding by adhesive Percentage of bonded surface: 30 %	Masonry of concrete units Mass of concrete units: 226 kg/m <sup>2</sup>	$\Delta R_w = 6$ dB $\Delta R_w + C = 5$ dB $\Delta R_w + C_{tr} = 5$ dB

### 3.2.6 Energy economy and heat retention (BWR 6)

#### a) Thermal resistance (EAD 040083-00-0404 – clause 2.2.23)

The additional thermal resistance  $R_{ETICS}$  provided by the ETICS to the substrate wall is calculated in accordance with EN ISO 6946 from the nominal value of the insulation product's thermal resistance  $R_D$  given accompanied to the CE marking and from the thermal resistance of the rendering system  $R_{render}$  which is about  $0.02 \text{ m}^2\cdot\text{K}/\text{W}$ :

$$R_{ETICS} = R_D + R_{render}$$

Thermal bridges caused by mechanical fixing devices influence the thermal transmittance of the entire wall and shall be taken into account.

The corrected thermal transmittance of the entire wall including ETICS and thermal bridges is calculated using the following expression:

$$U_c = U + \chi_p \cdot n$$

where:

$U_c$  corrected thermal transmittance of the entire wall including ETICS and thermal bridges ( $\text{W}/(\text{m}^2\cdot\text{K})$ );

$U$  thermal transmittance of the entire wall including ETICS without thermal bridges ( $\text{W}/(\text{m}^2\cdot\text{K})$ );

$n$  number of anchors (through insulation product) per  $\text{m}^2$ ;

$\chi_p$  point thermal transmittance value of an anchor ( $\text{W}/\text{K}$ ). See EOTA Technical Report No. 025. If not specified in the anchor's ETA, the following values apply:

=  $0.002 \text{ W}/\text{K}$  for anchors with a stainless steel screw with the head covered by plastic material and for anchors with an air gap at the head of the screw ( $\chi_p \cdot n$  negligible for  $n < 20$ );

= negligible for anchors with plastic nails (reinforced or not with glass fibres).

The term  $\chi_p \cdot n$  has only to be taken into account if it is greater than  $0.04 \text{ W}/(\text{m}^2\cdot\text{K})$ .

The thermal transmittance of the entire wall including ETICS without thermal bridges is determined as follows:

$$U = 1 / (R_i + R_{render} + R_{substrate} + R_{se} + R_{si})$$

where:

$R_i$  thermal resistance of the insulation product (see CE marking for ICB in reference to EN 13170) in  $\text{m}^2\cdot\text{K}/\text{W}$ ;

$R_{render}$  thermal resistance of the render (about  $0.02 \text{ m}^2\cdot\text{K}/\text{W}$ );

$R_{substrate}$  thermal resistance of the substrate (concrete, brick,...) in  $\text{m}^2\cdot\text{K}/\text{W}$ ;

$R_{se}$  external surface resistance in  $\text{m}^2\cdot\text{K}/\text{W}$ ;

$R_{si}$  internal surface resistance in  $\text{m}^2\cdot\text{K}/\text{W}$ .

### 3.2.7 Sustainable use of natural resources (BWR 7)

Performance not assessed.

### 3.2.8 Aspects of durability and serviceability

#### a) Bond strength after ageing

Results of the tests for determining the bond strength between the base coat and the insulation product presented in Table 5 show that in all cases the failure occurred in the ICB board (cohesion failure).

## 3.3 Component characteristics

### 3.3.1 General

Detailed information on the chemical composition and other identifying characteristics of the components, following EAD 040083-00-0404, has been deposited with LNEC.

Further information can be observed from the product data sheets, which are part of the Technical Documentation for this ETA.

### 3.3.2 Insulation product

Factory-prefabricated boards, made of expanded cork (ICB), having the description, characteristics and performances (as minimum) defined in Table 10 (EN 13170).



**TABLE 10**  
Characteristics of insulation panels

Component	Trade name	Characteristics	Declared values and classes
Insulation product	ISOVIT ICB	Reaction to fire (EN 13501-1+A1)	Euroclass E E (EAD 040083-00-0404 – clause 2.2.1.2) Density (EN 1602): 100 ± 10 kg/m <sup>3</sup> Thickness: 40 to 100 mm
		Thermal conductivity	0.040 W/(m.K)
		Classes of dimensional tolerances (EN 13163)	Thickness Class T2: ± 2 %, maximum ± 2 mm
			Length Class L2: ± 5 mm
			Width Class W2: ± 3 mm
		Compressive strength (EN 13163)	CS (10) 100: ≥ 100 kPa
		Tensile strength perpendicular to the faces in dry conditions (EN 1607)	TR 50: ≥ 50
		Shear strength and shear modulus of elasticity (NP EN 12090)	Shear strength: 68 ± 6 kPa Shear modulus of elasticity: 1100 ± 200 kPa

### 3.3.3 Render

– Render strip tensile resistance (EAD 040083-00-0404 – clause 2.2.17)

Fatigue tests were performed on specimens to determine the rupture stress of the reinforced render. The results are presented in Table 11.

**TABLE 11**  
Results of render strip tensile test

System specimen	Characteristics	Test results
Base coat + standard mesh	Tensile strength (N/mm)	21
	Tensile strength while the first crack is formed (N/mm)	17
	Crack width at relative elongation (mm)	0.01

### 3.3.4 Glass fibre meshes

The characteristics of the glass fibre meshes are presented in Table 12 (EAD 040083-00-0404 – clause 2.2.21).

**TABLE 12**  
Results of meshes tensile test

Component	Trade name	Characteristics	Test results
Standard mesh	ISOVIT REDE 160	Tensile strength after accelerated artificial ageing (N/mm)	20 (≥ 20)
		Relative residual resistance: % (after ageing) of the strength in the as delivered state	61 (> 50)
		Mass per surface unit (g/m <sup>2</sup> )	160 (± 5 %)
		Mesh dimensions (mm × mm)	5 × 4 (± 5 %)
Reinforced mesh	ISOVIT REDE 343	Tensile strength after accelerated artificial ageing (N/mm)	38 (> 20)
		Relative residual resistance: % (after ageing) of the strength in the as delivered state	67 (> 50)
		Mass per surface unit (g/m <sup>2</sup> )	330 (± 5 %)
		Mesh dimensions (mm × mm)	6 × 6 (± 5 %)

### 3.3.5 Anchors

Anchors for expanded polystyrene panels act as supplementary fixing if required. They are covered by ETA 16/0509, according to ETAG 014, used as EAD (see Table 1).

Their main characteristics for design are presented in Table 13.

**TABLE 13**  
Description and characteristics of anchors

Component	Trade name	Characteristics	Declared values and design data
Anchors	ISOVIT BUCHA	Anchor type	See dimensional characteristics in Annexes A5 and A6 of ETA 16/0509
		Materials	Anchor (expansion sleeve): polyethylene Nail: polyamide
		Resistance to tension loads (kN)	0.40 - 0.90 (see ETA 16/0509, Annex C2)
		Spacing (mm)	≥ 100
		Edge distance (mm)	≥ 100
		Thickness of the substrate (mm)	≥ 100

## 4. Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

According to the decision 97/556/EC of the European Commission of 14 July 1997<sup>3</sup> as amended by the decision 2001/596/EC<sup>4</sup> of 8 January of 2001, and considering the class B for the reaction to fire of the ETICS and that no stage in the production process has been identified that could result in an improvement of the reaction to fire characteristic, the system of assessment and verification of constancy of performance (see Annex V, as amended by Commission Delegated Regulation no. 568/2014 of 18 February 2014, and article 65 paragraph 2 to Regulation (EU) no. 305/2011) given in Table 14 applies.

**TABLE 14**  
System of assessment and verification of constancy of performance

Product	Intended uses	Levels or classes	System
ISOVIT CORK	External thermal insulation composite system with rendering for use on building walls	Any	2+

<sup>3</sup> Official Journal of the European Communities L229/14 of 20.08.1997.

<sup>4</sup> Official Journal of the European Communities L229/33 of 02.08.2001.

This system of assessment and verification of constancy of performance +2 is defined as follows:

System 2+: Declaration of the performance of the essential characteristics of the construction product by the manufacturer on the basis of:

- a) Tasks for the manufacturer:
  - (1) factory production control;
  - (2) testing of samples taken at the factory in accordance with the prescribed test plan.
- b) Tasks for the notified factory production control certification body:
  - (3) decision on the issuing, restriction, suspension or withdrawal of the certificate of conformity of the factory production control on the basis of the outcome of the following assessments and verifications carried out by that body:
    - initial inspection of the manufacturing plant and of factory production control;
    - continuous surveillance, assessment and evaluation of factory production control.

## **5. Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**

### **5.1 General**

The ETA is issued on the basis of agreed data/information, deposited with LNEC, which identifies the product that has been assessed and judged. It is the manufacturer's responsibility to make sure that all those who use the kit are appropriately informed of the specific conditions laid down in this ETA, including its annexes.

### **5.2 Tasks for the manufacturer**

#### **Factory production control**

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed.

This production control system shall ensure that the product is in conformity with this ETA.

The manufacturer may only use components stated in the technical documentation of this ETA. The incoming raw materials are subjected to verifications by the manufacturer before acceptance.

For the components of the ETICS which the manufacturer does not manufacture by himself, he shall make sure that the factory production control carried out by the other manufacturers gives the guarantee of the components compliance with the ETA.

The factory production control shall be in accordance with the Control Plan<sup>5</sup>, which is part of the Technical Documentation of this ETA. The Control Plan has been agreed between the manufacturer and LNEC and is laid down in the context of the factory production control system operated by the manufacturer and deposited within LNEC. The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

#### **Other tasks for the manufacturer**

The manufacturer shall, on the basis of a contract, involve a body (bodies) which is (are) notified for the tasks referred to in section 4 in the field of ETICS in order to undertake the actions laid down in this clause. For this purpose, the Control Plan shall be handed over by the manufacturer to the notified body (bodies) involved.

For assessing the ETICS and the components the results of the tests performed as part of the assessment for the ETA shall be used unless there are changes in the production line or plant. In such cases the necessary testing has to be agreed with LNEC.

The declaration of performance of the ETICS to be drawn up by the manufacturer following the issuing of this ETA shall include its reference number and issuing date.

Changes to the ETICS or the components or their production process should be notified to LNEC before the changes are introduced. LNEC will decide whether or not such changes affect the ETA and if so whether further assessment or alterations to the ETA shall be necessary.

<sup>5</sup> The Control Plan is a confidential part of this European Technical Assessment and is only handed over to the notified body or bodies involved in the procedure of assessment and verification of constancy of performance. See section 5.3.

### 5.3 Tasks for the notified body (bodies)

Within the scope of the initial inspection of factory and of factory production control, the notified body (bodies) shall ascertain that, in accordance with the Control Plan, the factory (in particular the employees and the equipment) and the factory production control are suitable to ensure continuous and orderly manufacturing of the components according to the specifications mentioned in this ETA.

Within the scope of continuous surveillance, assessment and evaluation of factory production control, the notified body (bodies) shall visit the factory at least once a year for surveillance. It has to be verified that the factory production control is maintained in suitable conditions.

These tasks shall be performed in accordance with the provisions laid down in the control plan.

The notified body (bodies) shall retain the essential points of its (their) actions referred to above and state the results obtained and conclusions drawn in a written report.

The notified body involved by the manufacturer shall issue a certificate of conformity of the factory production control stating the conformity with the provisions of this ETA.


In cases where the provisions of the ETA and its control plan are no longer fulfilled, the notified certification body shall withdraw the certificate of conformity and inform LNEC without delay.

Issued in Lisbon on 28/02/2022

By


Laboratório Nacional de Engenharia Civil (LNEC)

THE BOARD OF DIRECTORS

A handwritten signature in black ink, appearing to read 'Laura Caldeira', is positioned above the printed name and title.


Laura Caldeira  
President

## Annex 1



1. Insulation product
2. Profile


Vertical section of a window opening



1. Insulation product
2. ISOVIT PERFIL Corner profile with window
3. Base coat ISOVIT E-CORK
4. Insulation ISOVIT ICB
5. Adhesive ISOVIT E-CORK
6. Substrate
7. Insulation ISOVIT ICB
8. ISOVIT PERFIL Corner profile (with glass fibre mesh)
9. Finishing coat

Horizontal section of a window opening


## Annex 2



Horizontal section of corner with profile

1. Substrate
2. Adhesive ISOVIT E-CORK
3. Insulation ISOVIT ICB
4. Base coat ISOVIT E-CORK with glass fibre mesh (ISOVIT REDE 160)
5. ISOVIT PERFIL Corner profile (with glass fibre mesh)

## Annex 3



Vertical section of ETICS start

CDU	693.695:699.86(4)
	692.23:699.86(4)
ISSN	2183-3362

Descriptors:	Wall coating / External wall / Agglomerated cork / Thermal insulation / Composite material / / Europe
Descritores:	Revestimento de paredes / Parede exterior / Aglomerado de cortiça / Isolamento térmico / / Material compósito / Europa

